

Hydrology Operations Manual

Site Inspections: General

Water Level- Monthly (Flood warning only 2 monthly visits)

Parameter	Record Meter Number	Record time (5 / 15 minute punch)	Special instructions:	Record	Handheld Calibration / Validation	Site Calibration / Validation	Acceptable Deviation	Action
Water Level ESG	n/a	yes	Read to the nearest millimetre. Record error (smallest should be 3 mm). If surging note on form, and record the average level. If there is slope across the staff gauge record the value on the left hand side of the scale.	Staff gauge reading, staff gauge error & Logger Value	Laser and Levels annually	5 years	5 mm	Note o purgin long te up at le Check Check suspec
Water Level EPB	n/a	yes	Record EPB and logger readings.	EPB reading &Logger Value	Laser and Levels annually	5 years	3 mm	Note o purgin long te up at lo Check Check suspec
Water Level Continuous	yes	yes	(e.g. Radar, Pressure transmitter, shaft encoder) Read ESG, laser level or EPB to nearest mm.	Staff gauge reading, staff gauge error & Logger Value	As above	Monthly	5 mm	Note o purgin long te up at lo Check Check suspec
Water Level Flood Warning (not funded for water allocation / WQ quality)	yes	yes	(e.g. Radar, Pressure transmitter, shaft encoder) Read ESG, laser level or EPB to nearest mm.	Staff gauge reading, staff gauge error & Logger Value	As above	2 Monthly	10mm	Note of purgin long te up at l Check Check suspec
Ground Water Level	yes	yes	Record EPB or well probe and logger readings.	Well probe or EPB & Logger Value	Well Probes annually	3 Monthly	50 mm	Note o site bia checki at zero survey
Flow Meters	yes	yes	Record the logger values and meter values.	Meter value & Logger Value	Annually	Annually	2%	If outs pumpi rate te to esta fault, c

Section No: Page:



on if outside limits:

e on form, Non-conformance, and then consider sing/flushing the system and checking orifice/intakes. Check term trends for site bias. If in high flow then note for follow t lower stage for recheck. (Zero check PT's to check drift). ck system for water in gas equipment and float condition. ck condition of ESG and orifice, consider site survey if sect and time allows.

e on form, Non-conformance, and then consider sing/flushing the system and checking orifice/intakes. Check term trends for site bias. If in high flow then note for follow t lower stage for recheck. Zero check PT's to check drift. ck system for water in gas equipment and float condition. ck condition of ESG and orifice, consider site survey if sect and time allows.

e on form, Non-conformance, and then consider sing/flushing the system and checking orifice/intakes. Check term trends for site bias. If in high flow then note for follow t lower stage for recheck. Zero check PT's to check drift. ck system for water in gas equipment and float condition. ck condition of ESG and orifice, consider site survey if sect and time allows.

e on form, Non-conformance, and then consider sing/flushing the system and checking orifice/intakes. Check term trends for site bias. If in high flow then note for follow t lower stage for recheck. Zero check PT's to check drift. ck system for water in gas equipment and float condition. ck condition of ESG and orifice, consider site survey if sect and time allows.

e on form, Non-conformance. Check long term trends for bias. If inconsistent then consider purging the system and king orifice. Zero check PT's to check drift, should be offset ero head. Check condition of ESG and orifice, consider site ey if suspect and time allows.

tside then rate test and check pulse output consistency if pping, if not then schedule for next available opportunity. If test Passes then refer to consent holder and service agent stablish nature of fault If fails then suggests pulse output c, check with oscilloscope and resolve.



Hydrology Operations Manual

Site Inspections: General

Water Quality

(Monthly Visits)

Parameter	Record Meter Number	Record time (15 minute punch)	Special instructions:	Record	Handheld Calibration / Validation	Site Calibration / Validation	Acceptable Deviation	Action
Water Temperature	yes	yes	Sampled as close to the sensor as practical	Logger Value & Handheld	12 monthly	2 months	0.5 degrees	Note o check s
Dissolved Oxygen Saturation	yes	yes	Readings are only taken while the hand held sensor is stirred. (Flows above 0.3m/s do not require stirring)	Controller Value & Handheld	daily	12 monthly	8%	Note o clean s
Dissolved Oxygen Concentration	yes	yes	Readings are only taken while the sensor is stirred	N/A	daily	n/a	n/a	n/a
Conductivity	yes	yes	Readings as close to the sensor or pump intake as practical	Logger Value & Handheld	daily	12 monthly	50 µS	Note o recalib
рН	yes	yes	Readings as close to the sensor or pump intake as practical	Logger Value & Handheld	daily	3 monthly	1 pH units	Note o recalib
Turbidity	n/a	yes	Sampled as close to the sensor as practical. Note if cleaned. Sample if over 20 FNU.	Controller Values	n/a	samples	n/a	n/a

Weather (3 Monthly)

Parameter	Record Meter Number	Record time (15 minute punch)	Special instructions:	Record	Handheld Calibration / Validation	Site Calibration / Validation	Acceptable Deviation	Action
Rainfall	yes	Record time period when test tips occurred	Check gauge dipstick and flask or weight readings must be taken. Record each flask or weight reading on the form. Record the % difference between TB3/OTA and check gauge (primary/check gauge), manual tips and when they occurred, if a validation occurred, if anything was blocked, anything else that might affect the final data quality.	Dip stick reading Flask readings or scales Total Flask % deviation Test tips	Scales Annually	Annually	10%	Note c more t validat rainfal
Wind Speed	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Wind Direction	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Relative Humidity	yes	yes	Sampled as close to the sensor as practical	Hand held & Logger Value	Annually	n/a	n/a	n/a
Air Temperature	yes	yes	Sampled as close to the sensor as practical	Hand held & Logger Value	Annually	n/a	0.8 degrees	Note o check s
Barometric Pressure	yes	yes	Handheld Calibrated to the Victoria Street Sensor	Hand held & Logger Value	monthly	annually	3 hPa	Note o recalib
Soil Moisture	n/a	n/a	Do not disturb sensor	n/a	n/a	n/a	n/a	n/a
Soil Temperature	n/a	n/a	Do not disturb sensor	n/a	n/a	n/a	n/a	n/a

© Horizons Regional Council 2012



on if outside limits:

e on form, Non-conformance, Ensure field meter is correct, sk settings (4-20mA etc), replace sensor.

e on form, Non-conformance, Ensure field meter is correct, n sensor / inspect for damage. Replace sensor if needed.

e on form, Non-conformance, Ensure field meter is correct, librate field sensor / replace if needed.

e on form, Non-conformance, Ensure field meter is correct, librate field sensor / replace if needed.

on if outside limits:

e on form, Non-conformance. If the primary rain gauge is e than 10% off the flask reading or scales reading, perform a lation or schedule a validation in accordance with the fall procedure. Check Long term trends.

e on form, Non-conformance, Ensure field meter is correct, ck settings (4-20mA etc) replace sensor.

e on form, Non-conformance, Ensure field meter is correct, librate / replace field barometer.